

FORD ANALYTICAL LABORATORIES

CHEMICAL AND BACTERIOLOGICAL ANALYSIS

RECEIVED**FEB 1 1 1993****CERTIFICATE OF ANALYSIS**

DATE: 11/18/92

002232

S.L. COUNTRY CLUB
2400 COUNTRY CLUB DR
SALT LAKE CITY, UT
84109

WATER RIGHTS
SALT LAKE

92-027992

SAMPLE: DRINKING WATER SAMPLE FROM WELL AT COUNTRY CLUB RECEIVED
10-30-92 FOR INORGANIC ANALYSIS STARTING AT 13:45.

RESULTS**REPORTING
LIMIT**

	RESULTS	REPORTING LIMIT
Alkalinity, CaCO ₃ mg/l EPA310.2	250	5.0
Aluminum Al mg/l EPA 200.7	.24	.05
Antimony Sb mg/l EPA 204.2	<.027	.003
Arsenic As mg/l EPA 206.2	.003	.001
Barium Ba mg/l EPA 200.7	.046	.002
Beryllium Be mg/l EPA 210.2	<.004	.001
Cadmium Cd mg/l EPA 213.1	BRL	.003
Calcium Ca mg/l EPA 200.7	116	.01
Chloride, Cl mg/l EPA 300	130	.50
Chromium Cr mg/l EPA 218.1	BRL	.03
Color pt-co unit EPA 110.3	BRL	5
Cond. umhos/cm EPA 120.1	1480	.1
Copper Cu mg/l EPA 220.1	<.03	.02
Fluoride, F mg/l EPA 340.2	.42	.10
Iron Fe mg/l EPA 236.1	.17	.03
Langlier Index	.19	
Lead Pb mg/l EPA 239.2	BRL	.001

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or, extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.